



DATE: May 5, 2021
 TO: Yachats City Manager
 FROM: Public Works Department
 SUBJECT: April 2021 Public Works Report

Summary

This report provides key water metrics and a summary of projects and tasks performed by Public Works staff for the month of April 2021.

Inches of Rain Fall at Yachats Public Works	2021	2020	2019	2018
April	1.11	3.33	9.11	8.32
Rainfall To Date (same time period)	25.64	29.23	30.61	34.14

Total Measurement	
Water Production:	4,476,300 gallons
Water Sold:	3,799,900 gallons
Water Loss Efficiency:	85 %
Wastewater Treated:	4,059,000 gallons

Specific Tasks Performed

Streets	<ul style="list-style-type: none">●Pot holes filled on King St.●Compiling street sign replacement list for next budget year.
Drainage	<ul style="list-style-type: none">●Culvert inspections.
Water Treatment Plant	<ul style="list-style-type: none">●Water systems operations.●Plant maintc. & clean-up.
Distribution System	<ul style="list-style-type: none">●Meter reading.●Meter maintenance.●Water distribution system flushing.●Staff leak detection found three water system leaks.
Wastewater Treatment Plant	<ul style="list-style-type: none">●Wastewater systems operations.●Plant maintc. & clean-up.●Biosolids operations.●Equipment repair.
Collection System	<ul style="list-style-type: none">●Lift station inspections.●Inflow & Infiltration inspections.●Cleaned 320 feet of sewer main on W. 7th St. and 40 feet at Riverside lift station.●Contractor repaired 60-75 gallon per minute infiltration leak in a sewer main at Riverside lift station.●Parkside pump #2 sent out for maintc.
Public Works	<ul style="list-style-type: none">●Shop maintc. and clean up.●Fleet maintc. & repair.●Yard clean-up.●Equipment maintc. and repair.●Multiple locates.●Brush box handling.●PW administration.●Fueled equipment.
Parks & Trails	<ul style="list-style-type: none">●Piles picked up for Trails.
COVID-19	<ul style="list-style-type: none">●30 minutes spent daily to discuss safety measures and disinfecting the Public Works area.●Crew is using appropriate PPE where appropriate.