

Date: June 2, 2022
To: Heide Lambert, City Manager
From: Public Works Department
Re: May 2022 Public Works Report

Rainfall at Yachats Public Works:

	<u>Inches</u>			
	2022	2021	2020	2019
May	7.60	1.88	5.48	1.92
Rain year to date:	30.85	27.52	31.38	32.53

Total water production: **3,508,300 gallons** Water loss efficiency: **93%**

Total water accounted for: **3,263,985 gallons**

Total wastewater treated: **8,243,000 gallons**

The following is a list of what was done by Public Works staff in May 2022.

Streets:

- Multiple potholes filled.
- Cone stenciling.

Storm Drainage:

- Drainage inspections and maintc.

Water Treatment Plant:

- Water systems operations.
- Plant Maintc.
- Cleaned Reedy Creek screen.
- Meter reading.
- Floor painting.

Distribution Sys:

- Meter reading.
- Meter maintc.
- Installed two water service connections.
- Began installing water service line on Horizon Hill.

Wastewater Treatment Plant:

- Wastewater systems operations.
- Plant maintc. & clean-up.
- Biosolids operations.

Collection Sys:

- Lift station inspections.
- Degreased Lift Stations.
- Sewer jet and CCTV'd 280ft of sewer main on Combs Circle.
- Sewer jet and CCTV'd 460ft of sewer main on Hwy 101 S.
- CCTV'd 340 ft of sewer main on Hwy 101 N.
- Pump #2 failure at Main lift station. Sent out for repairs.
- Electrical issue at Riverside lift station. Repaired.

Public Works:

- Shop maintc. and clean up.
- Fleet maintc. & repair.
- Equipment maintc. and repair.
- Multiple locates.
- Brush box handling.
- PW administration.
- Piles picked up for Trails crew.
- Leads working on budget issues.
- Installed window cover at the library.
- Installed Summer banners.
- Banner repairs.
- Brush cutting on Hwy 101 & Yachats River Road, also on King St.
- Vac-Truck service required and performed.
- Limbs trimmed at City Hall parking lot.
- Flag maintc. and installed.
- High limbing on E.3rd St.

Parks, Commons and City Hall:

- Misc. work orders.