

Date: September 2, 2022
To: Heide Lambert, City Manager
From: Public Works Department
Re: August 2022 Public Works Report

Rainfall at Yachats Public Works:

	<u>Inches</u>			
	2022	2021	2020	2019
August	0.09	0.23	0.63	0.21
Rain year to date:	35.79	29.97	34.50	34.87

Total wastewater treated: **4,178,000 gallons**

The following is a list of what was done by Public Works staff in August 2022.

Streets:

- Side-arm Mowing.

Storm Drainage:

- Gender storm drain culvert installation.
- Side-arm Mowing.
- Ditch clearing on Reeves Circle.
- Storm drain maintenance.

Water Treatment Plant:

- Water systems operations.
- Plant Maintc.
- Cleaned Reedy Creek screen.
- WTP PLC failure. Repaired

Distribution Sys:

- Meter reading.
- Meter maintc.
- Leak inspections.

Wastewater Treatment Plant:

- Wastewater systems operations.
- Plant maintc. & clean-up.
- Biosolids operations.
- Truck load of biosolids sent to Heard Farm.

Collection Sys:

- Lift station inspections.
- Degreased Lift Stations.
- Pump #2 at Main lift station return to service.
- Main lift station PLC failure. Replaced.
- Riverside lift station junction box failure.
- CCTV'd 460 feet of sewer main on highway 101 N.

Public Works:

- Shop maintc. and clean up.
- Fleet maintc. & repair.
- Equipment maintc. and repair.
- Multiple locates.
- Brush box handling.
- PW administration.
- Piles picked up for Trails crew.
- Fire extinguisher inspections.

Parks, Commons and City Hall:

- Misc. work orders.