

Date: September 4, 2022
To: Heide Lambert, City Manager
From: Public Works Department
Re: September 2022 Public Works Report

Rainfall at Yachats Public Works:

	<u>Inches</u>			
	2022	2021	2020	2019
September	0.69	2.54	2.23	3.50
Rain year to date:	36.48	32.51	36.73	38.37

Total wastewater treated: **3,740,000 gallons**

The following is a list of what was done by Public Works staff in September 2022.

Streets:

- Side-arm Mowing.

Storm Drainage:

- Gender storm drain culvert installation complete.
- Culvert repair on Greenhill Drive.

Water Treatment Plant:

- Water systems operations.
- Plant Maintc.
- Cleaned Reedy Creek screen.
- Replaced lagoon pump.

Distribution Sys:

- Meter reading.
- Meter maintc.
- Water leaks repaired on Ocean View Drive, Hwy 101 S, and Shell Street.

Wastewater Treatment Plant:

- Wastewater systems operations.
- Plant maintc. & clean-up.
- Biosolids operations.
- SBR aerator replacement completed.

Collection Sys:

- Lift station inspections.
- Degreased Lift Stations.
- Cleaned and CCTV'd 300 feet on 9th Street and 289 feet on Hwy 101 S.

Public Works:

- Shop maintc. and clean up.
- Fleet maintc. & repair.
- Equipment maintc. and repair.
- Multiple locates.
- Brush box handling.
- PW administration.
- Piles picked up for Trails crew.
- Equipment fueling.
- Fire extinguisher inspections.

Parks, Commons and City Hall:

- Misc. work orders.